
Oakland County Campus

1200 N Telegraph Pontiac, MI 48341

Square Ft	1,939,560	Wall Construction	Varies	Heating	Varies
Year Built	Varies	Roof Construction	Varies	Cooling	Varies
Additions	Varies	Interior Lighting	Varies	Distribution	Varies
DHW	Varies	Exterior Lighting	Varies		
Please Note -	Square Ft represents	s totals of all on and off c	ampus buildings.	Temp Cont.	Varfies

Steam Consumption Profile



Year	Lbs	Cost	
2012	106,985,282	\$1,016,361	
2013	125,682,282	\$1,193,982	
2014	120,660,015	\$1,146,281	
2015	118,711,916	\$1,149,604	
2016	118,407,807	\$1,124,874	
2017	114,764,763	\$1,092,469	
2018	117,953,179	\$1,116,922	
2019	123,554,975	\$1,174,484	
2020	128,942,049	\$1,224,946	
2021	139,854,042	\$1,318,507	
2022	130,975,586	\$1,244,268	
2023	129,562,180	\$1,248,875	
Totals:	1,476,054,076	\$14,051,573	

Cost/sq.ft.: \$7.24 per sq.ft./yr. **Steam EUI: 763,308 BTU/sq.ft.**Avg. Cost: \$0.010 / lb.

Oakland County Campus Page 2